

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING NO: 7300-1516:101

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: AES Corporation, 285 Newbury Street, Peabody, MA 01960
Contact: Thomas Kenty (978) 535-7310 Fax (978) 535-7313

DESIGN: Model IntelliNet two way RF system. Unit is consisting of Models 7700 Network Controller, 7701 Central Station Receiver and 7730 Transceiver. The system is intended to serve as a front end receiver for UL listed central station system. System components:

65510/SBC	Bandpass Filter
7134T, E041	Display monitor
P850A (LX-300)	Printer
ISOBAR 8 ULTRA	Transient Voltage Surge Suppressor
XP-1640	Class 2 Transformer

Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 16.5 VDC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, and UL label.

APPROVAL: Listed as a fire alarm central station receiving system when installed in accordance with NFPA 72 and permitted per codes.

10-01-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager